UK Sprinkler incidents 2016

	Date	Time	Location	Size m²	Type of premises	£ Value	Heads	System	Occ	Remarks
1	04/01/2016	08:56	Croydon, London		Retail			C		Fire in fan unit of refrigeration section
2	09/01/2016	06:00	Sheffield		Dwelling		3	D	1	Fire in mobility scooter outside property. Sprinklers prevent catastrophic ingress of fire
3	21/01/2016	20:27	Cheltenham		Academy		1	C		Fire in cleaners cupboard extinguished
4	23/01/2016	19:00	Wallsend, Tyneside		Dwelling		1	D	2	Fire in kitchen, bag left accidentaly on hob of cooker
5	30/01/2016	22:30	Shotton, Deeside	8000	Paper Mill		DR	C	20	Drencher system operated when trapped paper caught alight on conveyor. 20m²damage
6	31/01/2016	14:45	Gravesend		Care facility		1	R	1	Fire controlled by one sprinkler head: one fatality reported: under police investigation
7	15/02/2016	22:15	Leominster		Plastics factory		4	C		Fire in plastic extrusion machine: damage confined to machinery
8	18/02/2016	19:00	Birmingham	46000	Tyre production offices/warehouse		4	C		Fire destroys offices(unsprinklered) and sprinklers prevent ingress into warehouse
9	01/03/2016		Manchester		Factory		8	C		Fire in production machinery. Company offered no further details
10	05/03/2016	17:42	London		Serviced apartment block		3	M	180	Fire in air conditioning unit and ducting. High pressure mist system fitted throughout
11	08/03/2016	12:59	Hackney, London		Secondary School		1	C		Fire in toilet area on second floor. 1 head extinguished fire
12	19/03/2016	23:00	Bolton		Plastics Factory			C		Fire in plastic moulding machinery
13	24/03/2016	21:00	Blackwall, London		Flat in 9 storey block		1	R	75	Fat pan fire on cooker extinguished by one sprinkler head
14	25/03/2016	13:41	Islington, London	40 x40	Hotel (6 storey)		1	C		Fire in bin room caused by careless disposal of cigarette. Sprinklers contain fire
15	25/03/2016	17:00	Hillingdon, London	20 x 40	Care Home (3 storey)		1	R	23	Fire in kitchenette of staff area. One head extinguishes fire.
16	27/03/2016	22:40	Chelmsford		Flat in 14 storey block		1	R		Fat pan fire on 13th floor suppressed by one sprinkler head
17	11/04/2016	11:55	Glasgow	12000	Offices		1	C	150	Fire in light fitting in corridor of 6 storey offices of traditional construction
18	20/04/2016	19:30	Oxford		Underground car park		8	C		Fire in engine compartment of car suppressed by sprinklers: FRS extinguish
19	07/05/2016	01:50	Denby Dale, West Yorks		Mill building			C		Two fires reported in woolen mill. Sprinklers suppress, FRS extinguish
20	09/05/2016	17:00	Rainham, London		Recycling facility			C		Fire in pile of waste for use in bio-mechanical treament plant
21	17/05/2016	04:39	Grantham, Lincolnshire		Commercial turkey hatchery		1	C		Fire in tumble dryer in room constructed of sandwich panels. Sprinklers control fire
22	20/05/2016	13:15	London	5000	Industrial laundry		1	C	70	Fire in industrial dryer at commercial laundry. Sprinklers control and contain fire
23	24/05/2001	07:00	Belfast		Specialised manufacturer			C		Fire in specialised manufacturer. Sprinklers contain fire. No further info
24	27/05/2016	p.m.	Corby		Dwelling		1	D		Fire in Wok in kitchen. One concealed head activates to extinguish fire
25	31/05/2016	15:47	London		Office block		1	C	1100	Electrical fire in ground floor brasserie of 10 storey block. Fire extinguished (wet pipe)
26	07/06/2016	p.m.	London		Globe theatre		DR	C		Drencher activated after operation of FA call point. Not attended to in prescribed time
27	19/06/2016	11:45	Manchester		Debenhams store			C		Fire in 3rd floor store room, Sprinklers extinguish fire
28	26/06/2016	01:00	London		Office block and leisure complex		1	C	400	Electrical fire in gymnasium. 1 sprinkler head extinguishes fire. No injuries
29	29/06/2016	00:04	Epsom		Flat		1	R		Fire in open plan kitchen in flat at supported living block of accomodation
30	02/07/2016	13:00	Dartford		Tunnel			M		Vehicle fire in tunnel. Mist suppression activate to contain. FRS extinguish
31	09/07/2016	02:00	Oldham		Distribution depot	£6m	14	C		Transformer fire in warehouse with £6m worth of goods. Sprinklers contain FRS ext.
32	09/07/2016	12:24	London	30 x 30	Underground car park > level 3		1	C	400	Fire in rickshaw in underground car park of 20 storey bdg. Sprinklers extinguish fire
33	19/07/2016	01:29	Kirkcaldy		Flooring manufacturer		1	C		Fire in faulty diesel generator in 10m x 10m pump house
34	21/07/2016	21:06	Wandsworth, London		Recycling facility			C	41	Fire on conveyor belt: suppression systems prevent spread. Under control at 22:46
35	03/08/2016	11:42	Hounslow		Debenhams store in complex		1	C	1700	Fire in 5m x5m storeroom . 1 sprinkler head suppressed fire.FRS extinguish
36	29/08/2016	20:19	Ipswich		Car park in 6 storey office block		1	C		Fire in stacked cardboard in ground floor car park. Sprinklers almost extinguish fire
37	01/09/2016	15:15	Southwark		Flat in complex		1	R		Fire on cooker of 82 year old resident. Some cluttering . Sprinkler extinguish fire
38	03/09/2016	22:15	Chippenham		Semi conductor factory		1	C		Electrical fire in ground floor test area caused by roof collapse. Fire extinguished
39	06/09/2016	14:48	Shrewsbury	60 x 30	GRP plastics factory		7	C		Sprinklers stop fire from spreading through ducting. Factory saved
40	08/09/2016	11:24	Thurmaston , Leicester		Flat		2	R		Fire in firdge/freezer in kitchen of 9 storey flats. Sprinklers control...FRS extinguish
41	13/09/2016		Birmingham		Bin room at block of flats			?		Fire in bin room at 10 storey block of flats. Sprinklers contain...FRS extinguish
42	18/09/2016	05:26	Minster Lovell, Oxford		Plastics factory		1	C		Fire in moulding/drying machine. River fed supply. Sprinklers contain...FRS extinguish
43	20/09/2016		Birmingham		Bin room at block of flats			?		Fire in bin room at 11 storey block of flats. Sprinklers contain...FRS extinguish
44	01/10/2016	04:05	Gateshead		Bedroom in flat		1	R		Fire in waste bin in bedroom. Sprinkler contain FRS ext. No injuires
45	02/10/2016	18:22	Sutton on sea		Fire in home of vulnerable person			PPS	1	Fire Service find evidence of burn marks to clothing. Person uninjured
46	07/10/2016		Leeds		Glass storage and decor facility			X		Fire destroys building and 10,000 pallets of glass.....sprinklers decommissioned
47	07/10/2016	12:40	Leeds		vacant former printing works			X		Fire destroys building .....sprinklers decommissioned. 10 pumps and 2 aerials used
48	07/10/2016	14:10	Kings Lynn.....Palm Paper		Large Paper production facility			C		Fire in paper bales on drum of machine. Sprinklers contain: FRS extinguish
49	15/10/2016	18:01	Ilkeston		Fire in home of vulnerable person			PPS	1	Smoking materials set light to blanket of 96 year old.....fire extinguished...no injuries
50	20/10/2016	15:09	Bath.....Jolly's store	60 x 40	Combined retail and residential		1	C	50+	Fire in paper located in common parts to flats: 2hours Business interuption
51	23/10/2016	10:14	Linton, South Derbyshire		Fire in home of vulnerable person			PPS	1	Fire on cooker caused by build up of grease.....occupant treated for smoke inhalation
52	24/10/2016	11:51	Southwark		Specialised housing scheme		1	R		Fire in waste bin in bedroom of 32 flat unit. Sprinkler extinguishes . No injuires
53	26/10/2016	09:00	Clarkston, Scotland		High school		1	C		Fire in non teaching area. 1 head extinguished fire: 1 hour interruption to lessons
54	06/11/2016	22;00	Rickmansworth		House		1	R		Candle sets fire to curtains in beddrom of house. Sprinklers extinguish. £3k damage
55	09/11/2016		Doncaster		Bin room at block of flats		1	R		Fire in bin room. Sprinklers control fire, FRS extinguish
56	13/11/2016	02:10	Rugeley	63000	Amazon warehouse		4	C		Fire in 10m high racking at level 1 spread to levels 2 &3. Sprinklers contain: FRS ext
57	13/12/2016	11:32	Clydebank		High school		1	C	1300	Fire in toilet cubicle. Sprinklers contain fire. 2 hours disruption
58	18/12/2016	16:18	Bristol		Shopping complex		1	C		Fire in sore room of retail unit in large shopping complex. Sprinklers extinguish
59	20/12/2016	23:59	Liverpool		Restaurant			C		Fire in 3rd floor plant room at Jamie's Italian restaurant. Sprinkler contain fire. FRS ext
60	21/12/2016	17:56	St Albans	40 x 30	Flat in low rise block		1	R	20	Electrical fire in ground floor flat of timber framed 3 storey block: £500 est. costs
61	28/12/2016		Ashton under Lyne		Commercial laundry		1	C		Fire in commercial dryer at industrial laundry. Sprinklers control, FRS extinguish
62	31/12/2016	17:11	Southampton	3000+	West Quay Shopping centre		1	C		Fire in fridge unit of 3 storey M&S store. Sprinklers control. FRS ext. £3000 est. loss
63										
64										
65										
66										
67										
68										
69										
70										
71										
72										
73										
74										
75										
76										